

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0078:213 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADEMCO, 165 Eileen Way, Syosset, NY 11791
Contact: Harry Pashkoff (516) 921-6704 ext. 3056 Fax (516) 364-6953

DESIGN: Models 7810iR Internet Communication Module. Unit must be used with Model 685 digital receiver control unit (CSFM Listing No. 7165-0078:133) when used as a central station protected premise unit. Model 7810iR must connect to a UL Listed Receiver/Central Station Automation System (Protective Signaling Service) that automatically annunciates unrestored, off-normal conditions during the 24 hour test report. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and UL label.

APPROVAL: Listed as control unit accessory for use with listee's separately listed compatible fire alarm control units.

NOTE: Alarm system functions via the Internet have not been evaluated. Burglar, Home automation and remote access features have not been evaluated.

12-22-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager